



STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Resources
William Snodgrass Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor

December 10, 2021

FujiClean USA
Attn: Mr. Scott Samuelson
41-2 Greenwood Road
Brunswick, Maine, 04011

RE: FujiClean Residential models CE5, CE 7, CE10, CEN 5, CEN7, CEN10, Advanced Treatment Systems (ATS)

Dear Mr. Samuelson:

The Division of Water Resources (DWR) Land Based Systems Central Office has reviewed the information you presented seeking approval of FujiClean CE and CEN series advanced treatment systems. Based on the information you provided, DWR Land Based Systems Unit considers FujiClean's CE and CEN series units to be in compliance with Section 0400-48-01-.10 of the Regulations To Govern Subsurface Sewage Disposal Systems. The FujiClean CE and CEN series will be added to the list of approved advanced treatment systems. This approval is limited to those models listed and classified as Class I by NSF at: <http://www.nsf.org/Certified/Wastewater/>. However, all models listed are subject to review for compliance with the regulations.

It is important to note that any model for sale in Tennessee with an incorporated trash tank that is a lesser capacity than the minimum septic tank capacity as listed in 0400-48-01-.08(1) must be shown by NSF as having been successfully tested with the incorporated trash tank. Also, all pump tanks, incorporated or otherwise associated with an approved ATS are subject to the capacity requirements corresponding to the intended disposal system in the regulations.

Mr. Scott Samuelson
December 10, 2021
Page 2

FujiClean USA is responsible to report all new installations and a current list of authorized dealers, designers, and maintenance providers on January 2nd and July 1st of each year.

Failure of FujiClean USA., or its authorized representatives to continue to satisfy the requirements of 0400-48-01-.10 of the regulations could result in removal from the list of approved advanced treatment systems.

DWR looks forward to working together with you to build a strong and successful ATS program. We appreciate your interest in Tennessee. If you have any questions regarding this matter, I can be reached at (615) 898-6504.

Sincerely,



Fali Kapadia, Consultant II
Division of Water Resources
Land Based Systems Unit
Fleming Training Center
2022 Blanton Drive
Murfreesboro, TN 37130