



Maryland
Department of
the Environment

Larry Hogan, Governor
Boyd K. Rutherford, Lt. Governor

Ben Grumbles, Secretary
Horacio Tablada, Deputy Secretary

December 14, 2018

Scott Samuelson
FujiClean USA LLC
41-2 Greenwood Road
Brunswick, ME 04011

SUBJECT: Successful completion of FujiClean CEN-Series field verification.

Dear Mr. Samuelson:

The Best Available Technology (BAT) Review Committee has reviewed all the submitted documents and data and has approved the FujiClean CEN-Series as a Class I technology.

The Maryland Department of the Environment (MDE) appreciates your participation in the Bay Restoration Fund (BRF) program. MDE requires that the final effluent total nitrogen (TN) composite sampling average is below 30 mg/L. The FujiClean CEN-Series easily met the MDE nitrogen reduction requirement with an overall average TN less than 15 mg/L.

If you have any additional questions or concerns please contact me by phone at 410-537-3635 or email at travis.sterner@maryland.gov

Sincerely,

A handwritten signature in blue ink, appearing to read "Travis E. Sterner".

Travis E. Sterner
BRF, BAT Section Head

cc:

Naomi Howell, MDE
Dr. Ching-Tzone, MDE
Dwayne Jones, Local Vendor