

DIGITAL PANEL WITH TIMED DOSE CONFIGURATION

*****FACTORY JUMPER BETWEEN BREAKERS MUST BE REMOVED FIRST*****

AERATOR & PUMP IF USED
LOAD NEUTRALS IN (WHITE)
#2 SPOT ON TERMINAL BLOCK

L1 POWER IN (BLACK)
AERATOR & PUMP
20 AMP BREAKER

L2 POWER IN (BLACK)
CONTROL & ALARM
15 AMP BREAKER

L1 & L2 NEUTRALS IN (WHITE)
#1 ON TERMINAL BLOCK

ALL GROUND WIRES
ON GROUND LUG

PUMP HOT LEAD IN (BLACK)
#3 ON TERMINAL BLOCK

ON / OFF FLOAT LEAD IN
(WHITE)
#5 ON TERMINAL BLOCK

ON / OFF FLOAT LEAD IN
(BLACK)
#6 ON TERMINAL BLOCK

AERATOR HOT LEAD IN
(BLACK) #4 ON TERMINAL
BLOCK

ALARM LEAD IN (WHITE)
#9 ON TERMINAL BLOCK

ALARM LEAD IN (BLACK)
#10 ON TERMINAL BLOCK

TIMER OVERRIDE FLOAT
LEAD IN (BLACK)
#8 ON TERMINAL BLOCK

TIMER OVER RIDE FLOAT
LEAD IN (WHITE)
#7 ON TERMINAL BLOCK

